

CLASS 125 CAST IRON SWING CHECK VALVE FLANGED ENDS

KITZ Fig : 125FC0

Sizes : 2~12inch(50~300mm)

BOLTED COVER, FLAT FACE FLANGED ENDS.

Standards :

- End to End : ASME B16.10 CLASS 125
- End Connection : ASME B16.1 CLASS 125
- Wall Thickness : KITZ STANDARD

Test Standard : KITZ St'd-2

Approvals : 2~12inch(50~300mm)

Standards : 2~12inch(50~300mm)

Dimensions

SIZE(inch/mm)		L	H	Approx (kg)
2	50	203.0	113.0	9.3
2 1/2	65	216.0	123.0	15
3	80	241.0	143.0	18
4	100	292.0	175.0	32
5	125	330.0	207.0	47
6	150	356.0	225.0	63
8	200	495.0	271.0	114
10	250	622.0	319.0	181
12	300	698.0	356.0	330

Material

Part Name	Material	Remark
BODY	CAST IRON	FC200
COVER	CAST IRON	FC200
DISC	CAST BRONZE	CAC406


Specifications

CLASS 125 CAST IRON SWING CHECK VALVE FLANGED ENDS

End Connection : ASME B16.1 CLASS 125, Sizes : 2~12inch(50~300mm),
 BODYMaterial:CAST IRON, COVERMaterial:CAST IRON, DISCMaterial:CAST
 BRONZE, KITZ Fig : 125FC0

※Images are for illustrative purposes only. The actual product may differ.

※For details, please refer to the submitted drawing.



[Fig Detail Page](#)

Pressure-temperature ratings and other performance data published in this catalog have been developed from our design calculation, in-house testing, field reports provided by our customers and/or published official standards or specifications. They are good only to cover typical applications as a general guideline to users of Kitz products introduced in this catalog. For any specific application, users are kindly requested to contact Kitz Corporation for technical advice, or to carry out their own study and evaluation for proving suitability of these products to such an application. Failure to follow this request could result in property damage and/or personal injury, for which we shall not be liable. Read instruction manual carefully before use.

KITZ

KITZ CORPORATION Tokyo Shiodome Building, 1-9-1, Higashi-Shimbashi, Minato-ku, Tokyo 105-7305, Japan
<https://www.kitz.com/en>

© Kitz Corporation. All Right Reserved.

ISO 9001
CERTIFIED
 Since 1989