

CLASS 300 CAST STAINLESS STEEL BALL VALVE FLANGED ENDS

KITZ Fig : 300UTDZM

Sizes : 1/2~8inch(15~200mm)

ANTI-STATIC DEVICE, FULL BORE, CONFORM TO ISO5211

Standards :

- End to End : ASME B16.10 CLASS 300
- End Connection : ASME B16.5 CLASS 300
- Wall Thickness : ASME B16.34 CLASS 300

Test Standard : API 598

Approvals : CE Marking 1/2~8inch(15~200mm)

Standards : 1/2~8inch(15~200mm)

Dimensions

SIZE(inch/mm)	L	H	D	Approx (kg)
1/2 15	140.0	108.0	130.0	3.0
3/4 20	152.0	111.0	130.0	4.5
1 25	165.0	124.0	160.0	7.0
1 1/4 32	190.0	134.0	230.0	8.9
1 1/2 40	216.0	143.0	230.0	9.9
2 50	241.0	179.0	400.0	17
2 1/2 65	305.0	251.0	750.0	26
3 80	502.0	406.0	1500.0	37
4 100	283.0	188.0	400.0	61
5 125	403.0	314.0	1000.0	88
6 150	381.0	267.0	750.0	107
8 200	178.0	128.0	133.0	240

Material

Part Name	Material	Remark
BODY	STAINLESS STEEL	A351 Gr. CF8M/SCS14A
BODY CAP	STAINLESS STEEL	A351 Gr. CF8M/SCS14A
STEM	STAINLESS STEEL	316SS
BALL	STAINLESS STEEL	A351 Gr. CF8M/SCS14A

Specifications

CLASS 300 CAST STAINLESS STEEL BALL VALVE FLANGED ENDS


End Connection : ASME B16.5 CLASS 300, Sizes : 1/2~8inch(15~200mm), Approvals : CE Marking, BODY Material: STAINLESS STEEL, BODY CAP Material: STAINLESS STEEL, STEM Material: STAINLESS STEEL, BALL Material: STAINLESS STEEL, KITZ Fig : 300UTDZM

※Images are for illustrative purposes only. The actual product may differ.

※For details, please refer to the submitted drawing.



PED



[Fig Detail Page](#)

Pressure-temperature ratings and other performance data published in this catalog have been developed from our design calculation, in-house testing, field reports provided by our customers and/or published official standards or specifications. They are good only to cover typical applications as a general guideline to users of KITZ products introduced in this catalog. For any specific application, users are kindly requested to contact KITZ Corporation for technical advice, or to carry out their own study and evaluation for proving suitability of these products to such an application. Failure to follow this request could result in property damage and/or personal injury, for which we shall not be liable. Read instruction manual carefully before use.

KITZ

KITZ CORPORATION Tokyo Shiodome Building, 1-9-1, Higashi-Shimbashi, Minato-ku, Tokyo 105-7305, Japan
<https://www.kitz.com/en>

© KITZ Corporation. All Right Reserved.

ISO 9001
CERTIFIED
 Since 1989