

KITZ Fig : T**Sizes :** 1/4~4inch(8~100mm)**STANDARD BORE, SCREWED ENDS.****Standards :**

- End to End :
- End Connection :
- Wall Thickness :

Test Standard : KITZ St'd-1**Approvals :** 1/4~4inch(8~100mm)**Standards :** 1/4~4inch(8~100mm)**Dimensions**

SIZE(inch/mm)		L	H	D	Approx (kg)
1/4	8	50.0	39.0	60.0	0.2
3/8	10	50.0	39.0	60.0	0.2
1/2	15	65.0	39.0	80.0	0.2
3/4	20	68.0	42.0	80.0	0.3
1	25	79.0	46.0	110.0	0.5
1 1/4	32	86.0	51.0	110.0	0.8
1 1/2	40	96.0	56.0	110.0	1.1
2	50	109.0	65.0	140.0	1.8
2 1/2	65	127.0	85.0	200.0	3.4
3	80	153.0	105.0	300.0	6.2
4	100	179.0	126.0	400.0	12.6

Material


Part Name	Material	Remark
BODY	FORGED BRASS	C3771
BODY CAP	FORGED BRASS	C3771
STEM	BRASS	C3531 (2)
BALL	FORGED BRASS	C3771 (3)

Specifications

Sizes : 1/4~4inch(8~100mm), BODYMaterial:FORGED BRASS, BODY CAPMaterial:FORGED BRASS, STEMMaterial:BRASS, BALLMaterial:FORGED BRASS, KITZ Fig : T

※Images are for illustrative purposes only. The actual product may differ.

※For details, please refer to the submitted drawing.



[Fig Detail Page](#)

Pressure-temperature ratings and other performance data published in this catalog have been developed from our design calculation, in-house testing, field reports provided by our customers and/or published official standards or specifications. They are good only to cover typical applications as a general guideline to users of KITZ products introduced in this catalog. For any specific application, users are kindly requested to contact KITZ Corporation for technical advice, or to carry out their own study and evaluation for proving suitability of these products to such an application. Failure to follow this request could result in property damage and/or personal injury, for which we shall not be liable. Read instruction manual carefully before use.

KITZ

KITZ CORPORATION Tokyo Shiodome Building, 1-9-1, Higashi-Shimbashi, Minato-ku, Tokyo 105-7305, Japan
<https://www.kitz.com/en>

© KITZ Corporation. All Right Reserved.

ISO 9001
CERTIFIED
 Since 1989