

10K CAST STAINLESS STEEL Y TYPE STRAINER FLANGED ENDS

KITZ Fig : UYB

Sizes : 3/8~2inch(10~50mm)

Standards :

- End to End : KITZ STANDARD
- End Connection : JIS B2220 10K
- Wall Thickness : KITZ STANDARD

Test Standard : KITZ St'd-2

Approvals : RoHS 3/8~2inch(10~50mm)

Standards : 3/8~2inch(10~50mm)

Dimensions

SIZE(inch/mm)		L	H	Approx (kg)
3/8	10	110.0	50.0	1.3
1/2	15	120.0	58.0	1.6
3/4	20	130.0	66.0	2.0
1	25	150.0	78.0	3.4
1 1/4	32	170.0	93.0	4.4
1 1/2	40	190.0	103.0	5.4
2	50	220.0	121.0	7.7

Material

Part Name	Material	Remark
BODY	STAINLESS STEEL	A351 Gr. CF8/SCS13A
COVER	STAINLESS STEEL	A351 Gr. CF8/SCS13A

Specifications

10K CAST STAINLESS STEEL Y TYPE STRAINER FLANGED ENDS

End Connection : JIS B2220 10K, Sizes : 3/8~2inch(10~50mm), Approvals : RoHS, BODYMaterial:STAINLESS STEEL, COVERMaterial:STAINLESS STEEL, KITZ Fig : UYB

※Images are for illustrative purposes only. The actual product may differ.

※For details, please refer to the submitted drawing.



RoHS



[Fig Detail Page](#)

Pressure-temperature ratings and other performance data published in this catalog have been developed from our design calculation, in-house testing, field reports provided by our customers and/or published official standards or specifications. They are good only to cover typical applications as a general guideline to users of KITZ products introduced in this catalog. For any specific application, users are kindly requested to contact KITZ Corporation for technical advice, or to carry out their own study and evaluation for proving suitability of these products to such an application. Failure to follow this request could result in property damage and/or personal injury, for which we shall not be liable. Read instruction manual carefully before use.

KITZ

KITZ CORPORATION Tokyo Shiodome Building, 1-9-1, Higashi-Shimbashi, Minato-ku, Tokyo 105-7305, Japan
<https://www.kitz.com/en>

© KITZ Corporation. All Right Reserved.

ISO 9001
CERTIFIED
 Since 1989